

TECHNICIAN'S CHECKLIST

SECTION 1606

EROSION CONTROL ROADSIDE DEVELOPMENT - SPECIAL SEDIMENT CONTROL FENCE

PROJECT: _____

TECHNICIAN: _____

REVIEW DATE: _____

REVIEWER: _____

ACTION	YES	NO	N/A	COMMENTS
Check the environmental permits to ensure that the fence is placed in the proper location and in accordance with the permit drawings and provisions. Ensure fence materials meet the requirements of Sections 1606.				
Ensure silt fence is being installed in advance of the need to contain sediment.				
Make any necessary additions in special sediment control fence.				
Ensure that materials are installed according to plan details. (See Roadway Standard Drawing No. 1606.01).				
Remove silt accumulation when silt reaches half the height of the stone and dispose of waste properly.				
Measure the silt removed for payment.				
Remove fence, posts and stone when the permanent controls have been established. Do not leave the stone piled at the toe of slope and do not place any stone in permitted areas.				